

Message

From: Mark Harrison [mharrison@facil.umass.edu]
Sent: 12/29/2010 7:00:33 PM
To: Edward J. Mientka [ejm@ehs.umass.edu]; Patrick T. Archbald [archbald@admin.umass.edu]
CC: 'Hanchett, James (DPH)' [James.Hanchett@state.ma.us]; Daniel McCarthy [dmccarthy@admin.umass.edu]; Bob Budrewicz [rbudrewicz@facil.umass.edu]; 'Jim Meade' [MEADE@gw.housing.umass.edu]
Subject: RE: New Card Access Doors for WMPH

Ed:

I cannot speak to what the access process would be. I will leave that to you and Jim Hanchett to work out.

Mark

From: Edward J. Mientka
Sent: Wednesday, December 29, 2010 1:43 PM
To: Mark Harrison; Patrick T. Archbald
Cc: 'Hanchett, James (DPH)'; Daniel McCarthy; Bob Budrewicz; 'Jim Meade'
Subject: RE: New Card Access Doors for WMPH

Hi Mark,

I assume that these are interior doors (drug lab etc.) and not exterior (building) doors. If so, that is ok....However, if access to the rooms is required say for a fire alarm investigation what is the process to get access?

Ed

From: Mark Harrison
Sent: Wednesday, December 29, 2010 8:50 AM
To: Edward J. Mientka; Patrick T. Archbald
Cc: 'Hanchett, James (DPH)'; Daniel McCarthy; Bob Budrewicz; 'Jim Meade'
Subject: New Card Access Doors for WMPH

Gentlemen:

We are preparing to bring online 4 new card access doors for Western Mass. Public Health. They have requested that these doors are not able to be accessed by anyone **including** first responders.

I would like to receive your acceptance of this before I configure the doors.

Thanks

Mark

*Mark D. Harrison
University of Massachusetts Amherst
Physical Plant IT Systems Administrator*

*Campus Door Access Systems Administrator
Physical Plant Building
360 Campus Center Way
Amherst, MA 01003*

*Office 413.545.6450
Cell [REDACTED]
Fax 413.545.2631
Email mharrison@facil.umass.edu*